

# The First Class A-1 Effluent Permit in Montana



Moonlight Basin, Big Sky Montana

## Topics

- Effluent Reuse
- Treatment Selection
- Design & Permitting
- Construction
- Project Challenges



# Regulation

## Montana DEQ Circular DEQ-2, Appendix B

### Class A-1 Standard

CLASS	TREATMENT STANDARDS
A-1	<p>Class A-1 reclaimed wastewater must, at all times, be oxidized, coagulated, filtered and disinfected, as described below or defined in this Appendix B. Class A-1 reclaimed wastewater that is treated to the standards below is exempt from ground water permit requirements pursuant to ARM 17.30.1022.</p> <p>Following treatment, Class A-1 reclaimed wastewater effluent quality should have approximately 10 mg/L or less of BOD and TSS.</p> <p>To achieve the turbidity requirements for Class A-1 reclaimed wastewaters, a treatment process that incorporates coagulation, flocculation, sedimentation and filtration is typically required. See Section 111 (Clarification Processes) for the required design standards.</p> <p>Class A-1 reclaimed wastewater must be disinfected such that the median number of total coliform organisms, in the wastewater after disinfection, does not exceed 2.2 colony forming units (CFU) per 100 milliliters, as determined from the bacteriological results of the last seven days for which analyses have been completed and such that the number of total coliform organisms does not exceed 23 CFU per 100 milliliters in any sample.</p> <p>Class A-1 reclaimed wastewater has the quality of effluent such that all constituents meet Montana nondegradation requirements prior to application, allowing it to be applied to land at rates that exceed the agronomic uptake rate. Specifically, total nitrogen must not exceed 5.0 mg/L at any time. Per MCA 75-5-410, reclaimed wastewater proposed for aquifer recharge or injection purposes must meet, at a minimum, secondary treatment, as defined in 40 CFR Part 133, and Level II treatment for the removal of nitrogen. For aquifer recharge proposals, the effluent quality must meet either primary drinking water standards or non-degradation requirements at the point of discharge. For aquifer injection proposals, the effluent quality must meet the more stringent of either the primary drinking water standards or the nondegradation requirements at the point of discharge. Soil aquifer treatment (infiltration/percolation basins) may not be considered in meeting these requirements.</p> <p>The minimum monitoring level required during periods of use (including prior to seasonal startup, if applicable) must include: continuous turbidity analysis with recorder, weekly total coliform analysis, and bi-weekly total nitrogen analysis. Weekly disinfectant residual analysis if chemical disinfection is being utilized.*</p>

Allowable Uses of Reclaimed Wastewater	Class of Reclaimed Wastewater Required for Identified Use						Allowable Uses of Reclaimed Wastewater	Class of Reclaimed Wastewater Required for Identified Use	Class of Reclaimed Wastewater Required for Identified Use													
	A-1	A	B-1	B	C	D			A-1	A	B-1	B	C	D								
							Decorative Fountains	(discharge to sewer)	YES	YES	NO	NO	NO	NO	NO							
								(discharge to groundwater)	YES	NO	NO	NO	NO	NO	NO							
							Jetting and Flushing of Sanitary Sewers		YES	YES	YES	YES	YES	YES	NO							
							Street Cleaning and Washing Operations															
							Street Sweeping, Brush Dampening		YES	YES	YES	YES	YES	YES	NO							
							Sidewalks and Parking Lot Washing, Spray		YES	NO	YES	NO	NO	NO	NO							
							Dust Control and Soil Compaction/Consolidation															
							Unpaved road dust control, road construction compaction, backfill consolidation around pipelines (Not Drinking Water lines)		YES	YES	YES	YES	YES	YES	NO							
							Fire Fighting and Fire Protection Systems															
							Dumping from Aircraft		YES	YES	YES	YES	YES	YES	NO							
							Hydrants or Sprinkler Systems in Buildings		YES	YES	NO	NO	NO	NO	NO							
							Toilet and Urinal Flushing		YES	YES	NO	NO	NO	NO	NO							
							Washing Aggregate and Concrete Batching Operations (no discharge)		YES	YES	YES	YES	YES	YES	NO							
							Industrial Uses															
							Aerosols not created (e.g. heat pumps, boilers) (non-discharging recirculation type)		YES	YES	YES	YES	YES	YES	NO							
							Aerosols or other mist created (e.g., cooling towers, forced air evaporation, or spraying)		YES	YES	NO	NO	NO	NO	NO							
							Aquifer Recharge															
							Controlled Surface or Subsurface Addition to Replenish the Aquifer **		YES	NO	NO	NO	NO	NO	NO							
							Aquifer Injection															
							Direct Injection into Aquifer for Purpose of Enhancing a Water Right or Allocation **		YES	NO	NO	NO	NO	NO	NO							
							Indirect Potable Reuse															
							Intentional Return of Reclaimed Wastewater to Augment Raw Water Supplies***		YES	YES	NO	NO	NO	NO	NO							
							Stream flow Augmentation															
							Fisheries Support, or Recreational Enhancement with Unrestricted Access ***		YES	YES	YES	YES	NO	NO	NO							
							Snow Making															
							Restricted Access – designed for discharge to groundwater		YES	NO	YES	NO	NO	NO	NO							
							Unrestricted Access – such as ski slopes***		YES	NO	NO	NO	NO	NO	NO							

## Treatment Selection

### Moonlight Basin Resort:

- Original Plant was a trickling filter system treating septic tank effluent. Disposal to drainfield.
- An oxidation ditch treatment plant replaced the original plant. Storage ponds and disposal to forest irrigation.



# Treatment Selection

## Preliminary Engineering Report

- Make Recommendations For Wastewater Treatment and Disposal

**Moonlight Basin  
Wastewater Treatment  
Plant Improvements**

Preliminary Engineering Report

October 2015

*Prepared for:*

**MB MT Acquisition, LLC**  
P.O. Box 160040  
Big Sky, MT 59716

*Prepared by:*

 **MORRISON-MAIERLE, INC.**  
PO Box 1113 • Bozeman, MT 59771  
406-587-0721 • F: 406-923-6702

MMI #: 3958.012

## Wastewater Treatment Alternatives

- Single MBR
- Existing Oxidation Ditch, 2 New Oxidation Ditches
- Existing Oxidation Ditch, 2 New SBRs
- Existing Oxidation Ditch, 2 New MBRs

## New Plant Effluent Disposal Options

- Golf Irrigation
- Surface Water Discharge
- Groundwater Discharge
  
- Class A-1 Compatible with Each Option






# Wastewater Treatment Selection

- Existing Oxidation Ditch, 2 New MBRs Selected

<b>Comparison Parameter</b>	<b>Parameter Weight</b>	<b>Single MBR</b>	<b>Exist OD + 2 New OD</b>	<b>Exist OD + 2 New SBR</b>	<b>Exist OD + 2 New MBR</b>
COST EFFECTIVENESS	5	2	3	3	4
TREATMENT RELIABILITY	4	4	3	3	4
OPERATIONAL EASE	3	2	4	3	2
FACILITY FLEXIBILITY	3	5	3	3	5
ENERGY/RESOURCE USE	2	3	4	3	3
<b>WEIGHTED RANK TOTAL</b>		<b>53</b>	<b>56</b>	<b>56</b>	<b>58</b>

## Design Pre-Selection

- Request for Proposals
- Solicitation from 3 Manufacturers
- Conducted Interviews
- Three Engineers Reviewed and Scored Proposals



# Design Pre-Selection

- Treatment Requirements

**INFLUENT FLOW CHARACTERISTICS**

Design Parameter	2018 <sup>1</sup>	2020 <sup>2</sup>	2030 <sup>3</sup>	2035 <sup>4</sup>
Annual Ave Day Flow, gpd	5,500	21,000	99,900	104,700
Maximum Month Flow, gpd	7,400	27,900	132,800	139,300
Maximum Day Flow, gpd	12,800	48,600	231,200	242,500
Peak Hour Flow, gpd	20,700	78,600	373,900	392,000
<sup>1</sup> 15% of Annual Average Flow <sup>2</sup> 20% of Annual Average Flow <sup>3</sup> 95% of Annual Average Flow <sup>4</sup> 100% of Annual Average Flow				

**ANNUAL AVERAGE INFLUENT LOAD CRITERIA**

Design Parameter	2018 <sup>1</sup>	2020 <sup>2</sup>	2030 <sup>3</sup>	2035 <sup>4</sup>
BOD <sub>5</sub> , lb/day	12	45	214	224
TSS, lb/day	5	18	87	92
Total Phosphorus, lb/day	0.3	1.2	5.8	6.1
TKN, lb/day	2	9	43	45
NH <sub>3</sub> -N, lb/day	2	8	37	39
<sup>1</sup> 15% of Annual Average Flow <sup>2</sup> 20% of Annual Average Flow <sup>3</sup> 95% of Annual Average Flow <sup>4</sup> 100% of Annual Average Flow				

**EFFLUENT DESIGN CRITERIA**


Design Parameter	Monthly Avg. Concentration	Maximum Concentration
NH <sub>3</sub> -N	1 mg/L	1.5 mg/L
BOD <sub>5</sub> <sup>1</sup>	5 mg/L	10 mg/L
TSS <sup>1</sup>	5 mg/L	10 mg/L
Total Nitrogen <sup>1</sup>	5 mg/L	5 mg/L
Total Phosphorus	1 mg/L	2 mg/L
Turbidity	0.2 NTU	0.5 NTU
Total Coliform <sup>2</sup>	<2.2 CFU/100 mL	<23 CFU/100 mL
<sup>1</sup> Based on MDEQ Circular DEQ-2 Class A-1 Reuse. <sup>2</sup> UV disinfection follows MBR		

# Design Pre-Selection

- MBR Requirements

Design Parameter	Requirement	
<b>Influent Characteristics</b>		
Temperature Range	8-18	°C
Alkalinity	236	mg/L as CaCO <sub>3</sub>
<b>Membranes</b>		
Number of Membrane Trains (N+1)	3	Minimum
Membrane Type	Ultrafiltration	
Nominal Membrane Pore Size	0.01 – 0.1	µm
Net Flux Rate (Max Day @ 8°C)	10	<u>gfd</u>
Net Flux Rate (Peak Hour @ 8°C)	20	<u>gfd</u>
Design Mixed Liquor Suspended Solids	6,000-12,000	mg/L
<b>System Parameters</b>		
Number of Biological Process Trains (N+1)	3	Minimum
RAS/Mixed Liquor Recycle Rate	3-5 Q	x max month
Internal Mixed Liquor Recycle Rate	2-4 Q	x max month
Number of Process Pumps, Blowers, or Other Equipment (N+1)	3	Minimum
Standard Oxygen Transfer Efficiency (SOTE)	2	%/ <u>ft</u>
Alpha Factor (α)	0.5	max
Beta Factor (β)	0.95	max

# Wastewater Equipment/Process Pre-Selection





- Selected Suez (formerly GE)

## Wastewater Equipment/Process Pre-Selection

- 3 Train Bioreactors and Membrane Basins for Operational Flexibility
- 4 Stage Process- Pre Anoxic, Aerobic, Post Anoxic, Membrane Basin (Aerobic)
- Process Chemical Systems- Sodium Hydroxide, MicroC, and Alum
- Membrane Chemical Systems- Sodium Hypochlorite and Citric Acid
- ZW-500 Reinforced Hollow Fiber PVDF Membranes

# Wastewater Equipment/Process Pre-Selection











# Design- Process Flow Diagram




# Design- Hydraulic Profile




# Design- Main Building

Processes Housed  
Indoors, Separate  
Headworks, Separate  
Chemical Rooms,  
Operator Lab and  
Offices



## Design-Lower Level Area


Access to Equipment,  
Flooded Suction for  
Influent Pump Station,  
MBR Pumping Systems,  
NPW and Effluent  
Pumping Systems



# Design-Solids Handling

## Aerobic Digesters Equalization

## Screw Press Dewatering



## Permitting

- Plans and Specifications Review Submittal to DEQ, August 31, 2016
- Provided Additional Information About Storage Pond and Golf Irrigation.
- Approved by DEQ: January 23, 2017



# Permitting

- Monitoring Requirements

Year	Total Coliform	Total Nitrogen	BOD <sub>5</sub>	TSS
1	Weekly	Bi-weekly	Monthly	Monthly
2	Monthly	Monthly	Quarterly	Quarterly
3	Monthly	Quarterly	Quarterly	Quarterly
4 and beyond	Quarterly	Quarterly	Semi-annually	Semi-annually



## Construction

- Bids Due: January 2018
- Contractor- Dick Anderson Construction
- Original Contract Amount: \$8.36 M
- Work began May 2018
- Completed November 2019
- Final Amount: \$8.63 M



May 3, 2018

# Construction



July 3, 2018



August 3, 2018

# Construction



September 14, 2018



October 30, 2018

## Construction

- Challenge- Dry In For Work To Continue Through The Winter
- Pre-Engineered Steel Buildings



November 30, 2018

# Construction



January 7, 2019

# Construction



August 27, 2019

## Construction

- Start-Up and Seeding
- ~32,000 Gallons From Big Sky County Water & Sewer District



September 30, 2019

# Construction-Final Completion





## Construction-Final Completion



Fine Screens



Influent Pumps

## Construction-Final Completion



Bioreactors and UV



Bioreactors

## Construction-Final Completion



Process and Membrane Blowers



MBR Pumps

# Construction-Final Completion



Aerobic Digesters

## Challenges and Approaches

- Choosing Treatment and Disposal: Compile a PER to Study and Recommend a Solution
- 1<sup>st</sup> of a Kind Permitting: Research and Communicate with Regulators
- Existing Infrastructure: Permitting to Allow a New Use Includes Inspections, Testing, and Reports
- Construction: Managing Season and Suppliers
- Start-Up: Provide Initial Operational Support

# Questions?

Eric Blanksma, PE

[eblanksma@m-m.net](mailto:eblanksma@m-m.net)

406-495-3434