

Reviving the Heart of a Collection System

Reserve Street Lift Station

Missoula, MT






Poll Question

Do you have a lift station in your collection system?

Yes

No



Missoula


Missoula

East Missoula

Bonner

Kelly Island

Orchard Homes



Poll Question

How many lift stations do you have in your system?


1-2

2-5

6+

Lift Stations in Missoula


- 39 City-Owned Lift Stations
- 7 Privately-Owned Lift Stations
- 1,442 active STEP Systems





Lift Stations in Missoula

- 39 City-Owned Lift Stations
- 7 Privately-Owned Lift Stations
- 1,442 active STEP Systems

There is a lot of “lifting” in Missoula!




















Applying lessons learned

- How do we minimize the impact of groundwater
- Reduce the amount of bypass pumping
- Allow pumps to run longer, more efficiently



Depth of Existing Lift Station

- 37.61 FT
- GW = 30.3 FT

2525 Palmer Street, Suite 2
Missoula, MT 59808
Phone: (406) 543-3045
Fax: (406) 543-3088

Figure No. 1 LOG OF BORING



Sheet 2 of 2

Boring BH-1

Project: Missoula Lift Station		Rig: CME-850 Hammer: Auto	Boring Location N: 46.840649 Coordinates E: -114.040077
Project Number: 117-8225021		Boring Diameter: 8 in	System: Decimal Degrees Datum: NAD83 Top of Boring Elevation:
Date Started: 6/5/19	Date Finished: 6/5/19	Drilling Fluid: None	Abandonment Method: Backfilled with Cuttings
Driller: Haz-Tech Drilling, Inc. Logger: Andrew Warren		Location: Refer to Site Map	

Depth (ft)	Elev. (ft)	Operation	Sample Type	Recovery (%)	RQD (%)	Blow Count	Lithology	Material Description	Depth (ft)	Elev. (ft)	MC (%)	LL	PL	-200 (%)	DD	Remarks and Other Tests
			X	56		28 - 50/0.4ft										
35			X	21		12 - 18 - 50/0.4ft										
40			X	33		12 - 16 - 26										
45			X	47		12 - 16 - 46										
50																

Boring Depth: 50.0 ft, Elevation:

50.0

Applying lessons learned

- ✓ How do we minimize the impact of groundwater
- ✓ Reduce the amount of bypass pumping
- Allow pumps to run longer, more efficiently



If two are good is three better?



Poll Question

Do you have any lift stations with more than 2 pumps?

Yes

No

Yes, but just at the treatment plant

Evaluating Multiple Pumps (near-term)

Duplex System


- Each pump @ 2,500 gpm
- Motor = 125 hp
- Efficiency = 73%
- Weight = 900 lbs

Triplex or Quadplex System

- Each pump @ 1,000 gpm
- Motor = 15 hp
- Efficiency = 88 %
- Weight = 500 lbs


Previous 22 Month Average Flow






Data derived from SCADA data provided by City of Missoula from October 17, 2018 to November 21, 2018.
Individual lines not shown on the legend represent one day from this reporting period.

All SCADA Data		
Avg	Max	Min
539	1,037	198



Data derived from SCADA data provided by City of Missoula from October 17, 2018 to November 21, 2018.
Individual lines not shown on the legend represent one day from this reporting period.

Week Days		
Avg	Max	Min
533	843	198




Data derived from SCADA data provided by City of Missoula from October 17, 2018 to November 21, 2018.
Individual lines not shown on the legend represent one day from this reporting period.

Week Ends		
Avg	Max	Min
551	1,037	215


Design Flow Recommendations


- Current Design Peak Hourly Flow = 1,820 gpm
- Near Term Design Peak Hourly Flow = 2,020 gpm
- Future Design Peak Hourly Flow = 2,550 gpm








Design Recommendations

- 12-foot diameter wet-well
- 3 pumps with a 4th slot for future
- Each pump have a capacity of ~1,000 gpm







GENERAL NOTES:

1. INSTALL EQUIPMENT AND ACCESSORIES PER MANUFACTURER'S RECOMMENDATIONS. ALL EQUIPMENT INSIDE WET WELL SHALL MEET REQUIREMENTS FOR CLASS 1 DIVISION 1 LOCATION.
2. PRECAST CONCRETE LIDS AND MANHOLE SECTIONS SHALL CONFORM TO ASTM A938. CONTRACTOR SHALL VERIFY DIMENSIONS AND CONNECTION TYPE PRIOR TO ORDERING. JOINTS SHALL HAVE PERFORMED FLEXIBLE SEALANT MEETING ASTM C290.
3. CONTRACTOR SHALL INSTALL EXTERNAL JOINT WRAP ON ALL MANHOLE JOINTS EXPOSED TO AIR, USING EXTERNAL COATING. EXTERNAL JOINT WRAP SHALL BE UPPER PENNSYLVANIA RUBBER COMPANY (CAZULOC) CONCREAL (CS-312), OR APPROVED EQUAL.
4. CONTRACTOR SHALL APPLY AN EXTERNAL WATERPROOF COATING (MIN 40 MILS) TO WET WELL. SEE SECTION 0712 FOR DETAILS.
5. CONTRACTOR SHALL APPLY A SPRAY-ON LINER (MINIMUM 125 MILS) TO THE INTERIOR OF WET WELL AND MANHOLES. SEE SECTION 0950 FOR DETAILS.
6. SEE SECTION 0950 FOR DETAILS ON WET WELL AND VAULT ACCESS HATCHES.
7. ALL COATED IRON PIPE AND FITTINGS SHALL BE DELIVERED WITH HD ASPHALTIC COATING BUT RATHER A FACTORY APPLIED HIGH-SOLID EPOXY PRIMER. FINISH COATING SHALL BE FIELD APPLIED PER SYSTEM NO. 1 FROM SECTION 0950.
8. LEVEL TRANSDUCER AND FLOATS NOT SHOWN FOR CLARITY. SEE ELECTRICAL DRAWINGS FOR DETAILS.
9. ** DENOTES EQUIPMENT OR ITEMS SUPPLIED BY DWS OR 11 MANUFACTURER AS A COMPLETE PACKAGE. CONTRACTOR IS RESPONSIBLE FOR COORDINATING INSTALLATION ON ALL SUPPLIED EQUIPMENT AND INSTRUMENTATION.

REVISION	NO.	DESCRIPTION	BY	DATE
1	1	ISSUED FOR PERMIT	JAC	08/20/19
2	2	ISSUED FOR CONSTRUCTION	JAC	08/20/19
3	3	ISSUED FOR CONSTRUCTION	JAC	08/20/19
4	4	ISSUED FOR CONSTRUCTION	JAC	08/20/19
5	5	ISSUED FOR CONSTRUCTION	JAC	08/20/19

Morrison Maierle
engineers • surveyors • planners • architects

1 Engineering Place
Missoula, MT 59802
406.442.3050
www.m-m.com

APPROVED FOR CONSTRUCTION
DATE: 08/20/19

MONTANA
REAL ESTATE
COMMISSION
LICENSED PROFESSIONAL ENGINEER

EXAM BY: JAC
DESIGN BY: JAC
APPR BY: JAC
DATE: 08/20/19
C.C. REVIEW BY: JAC
DATE: 08/20/19

MISSOULA	RESERVE STREET LIFT STATION	MONTANA
LIFT STATION SECTIONS AND DETAILS		

PROJECT NUMBER 1627-019
SHEET NUMBER M-2

Construction Starts

- Notice to Proceed



Construction

- Colder Weather Comes




Construction

- Deep Excavation Begins



Construction

- Deep Excavation Continues
- Groundwater?





Construction

- Test for leakage



Construction

- Core the existing lift station



Construction

- Set the valve vault



Construction

- The valve vault was equipped



Construction

- Start setting pumps



Construction

- Reconnect forcemains and ...



Construction



Construction



Construction



Construction

- Paved the multiuse path




Construction



Reserve Street Lift Station Stats

- 4 pumps – 1,000 gpm each
- Design Capacity of 3,000 gpm
- Construction Cost - \$840,000
- Construction – 90 days



Next Steps

- Fine tuning of the pumps
- Monitor electrical usage



Questions?

Jason Mercer

Water-Wastewater Market Group Leader

(406) 495-3488

jmercerc@m-m.net



